

## 2013 HERS VERIFICATION SUMMARY - ALTERATIONS

SCOPE OF WORK	Duct Sealing All Climate Zones	Refrigerant Charge CZ's: 2, 8-15	Cooling Coil Airflow All Climate Zones	Fan Efficacy (Watt-Draw Ratio) All Climate Zones
New System	≤ 6%	Required ≤ 350 cfm/ton	≥ 350 cfm/ton Or prescriptive Sizing	≤ .58 W/cfm Or prescriptive Sizing
New System, with CFI	Efficacy Verified in ventilation mode* →			≤ .58 W/cfm Or prescriptive Sizing
New Duct System >75% and all accessible	≤ 6%	N/A	≥ 350 cfm/ton Or prescriptive Sizing	≤ .58 W/cfm Or prescriptive Sizing
Altered Duct System >40' in unconditioned space	≤ 15%	N/A	N/A	N/A
Altered Furnace or Air- Handler	≤ 15%	N/A	N/A	N/A
Altered Condensor of Coil	≤ 15%	N/A	N/A	N/A
Altered Refrigerant Component	N/A	≥ 300 cfm/ton Or prescriptive Sizing	N/A	N/A